

Office of the District Fire Officer
Karnataka State Fire
and Emergency Services
Khanapur Road, Belagavi-590001



Phone : 0831-2429441
E-Mail : dfobgv@gmail.com

C.NO/183/FSCR/DFO/BELAGAVI/2026

Date : 09-06--2026

To,
The Head Master,
Shree Pratapa Jadhaji Bhate English Medium High School,
Athani, Athani Taluk & Belagavi District

Sir,

Sub : Issue of 'Fire Safety Compliance Report' to Shree Pratapa Jadhaji Bhate English Medium High School, Athani, Athani Taluk & Belagavi District.

Ref: 1) C.NO/183/FSR/DFO/BELAGAVI/2026 Date : 02-06--2026
2) C.No:89/FSCR/FSO/Athani/2026 Date: 06-06-2026.

*_*_*_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of **Shree Pratapa Jadhaji Bhate English Medium High School**, building consisting with Lower Ground, Ground & 1 Upper floor situated at **Athani, Athani Taluk & Belagavi District** was inspected by The Fire Station Officer, Athani on 06-06-2026 with respect to fire Prevention, Fire Fighting & Evacuation point of view for the purpose of issuing **Fire Safety Compliance Report** and has submitted the details as under.

ANNEXURE-1

"GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01	Name and Address of the Applicant	The Head Master, Shree Pratapa Jadhaji Bhate English Medium High School, Athani, Athani Taluk & Belagavi District
02	Name and Address of the Premises	Shree Pratapa Jadhaji Bhate English Medium High School, Athani, Athani Taluk & Belagavi District
03.	Name and Address of the Building Owner	The Chairman, Jadhavaji Education Society Athani, Athani Taluk & Belagavi District.
04.	Number of Building	01
05.	Number of Floors	Lower Ground, Ground & 1 Upper Floor
06.	Floor-wise details of Occupancy:-	
	Lower Ground	Class Room-03, Office-01, Staff Room-01 & Store Room.
	Ground Floor	Class Room-05
	1 st Floor	Science Lab-01, Equipment Room-01 & Computer Lab-01.
07.	Height of the building	09.00 Mtr
08.	Site area	04 Acre 35 Gunta
09.	Built-up area of each floor:-	
	Lower Ground	350.80 Sq Mtrs

[Handwritten signature and date 09/06/26]

	Ground Floor	350.80 Sq Mtrs
	1 st Floor	350.80 Sq Mtrs
10.	Total Built-up area	1052.40 Sq Mtrs
11.	Surrounding properties:-	
	East	Road
	West	Old Tangadi Road
	North	Residential House
	South	J.A Kannada Medium High School
12.	Open Space all around the building	
	East	Nil
	West	15.00 Mtr
	North	01.00 Mtr
	South	05.50 Mtr
13.	U-Dise Number-	29300112902
	Allowed Setbacks (open space) should be maintained free from further obstruction/construction.	

B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

from fire safety point of view.				
Sl. No	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	Accessibility from Eastern side with 06.00 Mtr wide road		Adequate
02.	Number of Entrances	01 no. of 06.00 mtr wide		Adequate
03.	Number of Staircase	No of staircase	01 no.	Complied
		Width of the staircase	01.45 mtr	
		Width of threads	0.30 mtr	
		Height of risers	0.15 mtr	
		No of risers per flight	10	
		Height of the hand drill.	0.80 mtr	
04.	Portable Extinguishers	08 nos. of 6 Kg capacity ABC type& 01 no. of 4.5 Kg capacity CO2 type extinguisher has been provided. All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.		Complied
05.	Escape routes	Direction in which the students/teachers have to move in the event of emergency has been indicated in the corridor/passage as a guide during evacuation.		Complied.
06.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency has been displayed along with the telephone numbers of Athani Fire Station i,e 08289-251740, & 101 the telephone nos nearest ambulance services and police station.		Complied
07.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board		Complied

		is written in the English & Kannada both languages and is displayed inside the entry/exit.	
08.	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.	Complied
09.	Nominate One Fire Nodal Officer	Sri. Rajaram M Shindhe & Sri. Mounesh A Badiger are nominated as fire nodal officer	Nominated
10.	Fire Fighting Training	02 persons have undergone basic fire fighting training at Sheikh Group of Institutions College premises Belagavi on 19-04-2025 Sri. Rajaram M Shindhe Sri. Mounesh A Badiger	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.
11.	<u>Fire Precautionary Measures</u> <i>A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.</i> <i>B:-Accumulation of combustible waste in and around the premises should be avoided.</i> <i>C:- The Exit ways shall be always kept clear without any obstruction.</i> <i>D:-Liquefied petroleum gas should not be stored in the building.</i> <i>E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.</i> <i>F:- During the class hours the class room door shall not be locked from inside to out side.</i> <i>G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.</i>		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing “**Fire Safety Compliance Report**” to **Shree Pratapa Jadhaji Bhate English Medium High School, Athani, Athani Taluk & Belagavi District**. As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This “**Fire Safety Compliance Report**” is valid for only one year from the date of issue and is renewable.

Yours Faithfully


District Fire Officer
Karnataka State Fire And Emergency Services
Belagavi-01. 9/6/26

Copy to,
Fire Station Officer, Athani.



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ಉಪವಿಭಾಗ ಅಧೀನ
ಮೂರನಾಣಿ ಸಂಖ್ಯೆ-

ಇ-Mail-aeeppwdan1@gmail.com

ಕ್ರ.ಸಂಪನ್ಮೂಲ/ಲೋಕೋಪಯೋಗಿ/ರಾ.ಪ/ರಾ.ಪ/2025-26/1021

ದಿನಾಂಕ : 13/11/2025

Head Master
J.E.Society's Shri.Pratap Jadhavji Bhate
English Medium School Athani

ಮಾನ್ಯರೇ,

ಪ್ರಿಯತಮ-ಮಾನ್ಯರೇ, ಈ ಕೆಳಕಂಡಂತಿರುವ ಕೆಲಸಗಳನ್ನು ಪೂರ್ಣಗೊಳಿಸಿ ನೀಡುವ ಕುರಿತು.
ಈಗಾಗಲೇ ನಿರ್ಮಾಣಗೊಂಡಿರುವ ಕೆಲಸಗಳಿಗೆ Structural Stability
ನಿರೀಕ್ಷಣಾ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನೀಡುವ ಕುರಿತು.

- 1) ಮಾನ್ಯ ಸರ್ಕಾರ ಸುತ್ತೋಲೆ ಸಂಖ್ಯೆ ಲೋಕೋಪಯೋಗಿ 59 ದಿ.12/2019 ದಿನಾಂಕ-07-05-2022.
- 2) ಮಾನ್ಯ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ವಿಭಾಗ ಚಿಕ್ಕೋಡಿ
- 3) KLE Collage of Engineering & Technology Chikkadi ರವರ ಪತ್ರ ಸಂಖ್ಯೆ:396/ ದಿ:12-11-2025.
- 4) Head Master J.E.Society's Shri.Pratap Jadhavji Bhate English Medium School Athani ರ ಪತ್ರ ದಿ:17-11-2025.

ಮೇಲ್ಕಂಡ ವಿಷಯ ಹಾಗೂ ಉಲ್ಲೇಖ (1) ಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ ಅಧಿಕಾರಿಗಳು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ವಿಭಾಗ ಅಧೀನದಲ್ಲಿ ವಿವರಿಸಿದ್ದು.

ಉಲ್ಲೇಖ-4ರ ಸರ್ಕಾರ ಸುತ್ತೋಲೆಯ ನಿರ್ದೇಶನದಂತೆ ಈಗಾಗಲೇ ನಿರ್ಮಾಣಗೊಂಡ ಅಸ್ತಿತ್ವದಲ್ಲಿರುವ ಕಟ್ಟಡಗಳಿಗೆ ರಚನಾತ್ಮಕ (Structural Evaluation) ಮೌಲ್ಯಮಾಪನ ಮಾಡಿಸಿ National Building code ಮಾನದಂಡಗಳ ಅನ್ವಯ ಹಾಗೂ ಉಲ್ಲೇಖ (2)ರ ಪತ್ರದಲ್ಲಿ ಮಾನ್ಯ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ವಿಭಾಗ ಚಿಕ್ಕೋಡಿ ಇವರು ಸಹ ಈ ವರದಿಯಲ್ಲಿ ಸ್ಪಷ್ಟವಾಗಿ ಪ್ರಕಾರ ನಿರ್ಮಾಣ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನೀಡಲು ಸೂಚಿಸಿರುತ್ತಾರೆ.

ಸದರಿ ಪ್ರಸ್ತಾವನೆಯೊಂದಿಗೆ ಲಗತ್ತಿಸಿದ ನಮೂನೆಗಳನ್ನು ಪರಿಶೀಲಿಸಿದ್ದು Non Destructive test ಗಳನ್ನು ಕೈಗೊಂಡು ಕಟ್ಟಡವನ್ನು ಮೌಲ್ಯಮಾಪನ ಕೊರತೆಯಿರುವುದಾಗಿ ಪರಿಶೀಲಿಸಿ ಅಭಿಪ್ರಾಯವನ್ನು ನೀಡಲು S.N.J.P.N.Trusts Polytechnic Nidasoshi ದಿ:-12-11-2025. ಆದರೆ ಪ್ರತಿಯನ್ನು ಉಲ್ಲೇಖ-3 ರ ಪತ್ರದಲ್ಲಿ ಕಟ್ಟಡಕ್ಕೆ ಸಮಗ್ರವಾಗಿ ಇರುತ್ತದೆ.

ಈ ವಿಚಾರ ಪರಿಶೀಲಿಸಿ ಅಧಿಕಾರಿಗಳು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ವಿಭಾಗ ಅಧೀನದಲ್ಲಿ ವಿವರಿಸಿದ್ದು. ಮಾನ್ಯರೇ, ಈ ಕೆಳಕಂಡಂತಿರುವ ಕೆಲಸಗಳನ್ನು ಪೂರ್ಣಗೊಳಿಸಿ ನೀಡುವ ಕುರಿತು.
ಮಾನ್ಯರೇ, ಈ ಕೆಳಕಂಡಂತಿರುವ ಕೆಲಸಗಳನ್ನು ಪೂರ್ಣಗೊಳಿಸಿ ನೀಡುವ ಕುರಿತು.
ಪತ್ರ ಸಂಖ್ಯೆ 05 ವರ್ಷದ ಅವಧಿಯಲ್ಲಿ ಈ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಈ ಕೆಳಗಿನ ನಿಬಂಧನೆಗಳೊಳಗೆ ನೀಡಲಾಗಿದೆ.

- 1) ಕಟ್ಟಡದಲ್ಲಿ ಯಾವುದೇ ಬದಲಾವಣೆ ಮಾಡಬೇಕಾದಲ್ಲಿ ಪಾಂಚಿಕ ಸಲಹೆ ಪಡೆದು ಕೈಗೊಳ್ಳುವುದು.
- 2) ಕಟ್ಟಡದ ನಿರ್ಮಾಣದ ವಿವರವನ್ನು ಕಾಲಾನುಕಾಲಕ್ಕೆ ಕೈಗೊಳ್ಳುವುದು.
- 3) ಸದರಿ ಕಟ್ಟಡವನ್ನು ಕಾಲಾನುಕಾಲಕ್ಕೆ ಪರಿಶೀಲಿಸುವುದು.

ತಮ್ಮ ವಿಶ್ವಾಸದ.

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ಉಪ ವಿಭಾಗ ಅಧೀನ



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಸಮಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧಿಯಂತರರು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ಉಪವಿಭಾಗ ಅಥಣಿ

ಮೂರನೇ ಸಂಖ್ಯೆ:-

e-Mail-aespwdan1@gmail.com

ಕ್ರಮ:ಸಕಾನಿ/ಲೋಕ/ಉಪಿಆ/ಉ ಪ/2025-26/1021

ದಿನಾಂಕ : 13/11/2025

Head Master

J.E.Society's Shri.Pratap Jadhavji Bhat
English Medium School Athani

ಮಾನ್ಯರೇ,

ವಿಷಯ:-ಬಾಸಗಿ ಅನುದಾನಿತ ಅನುದಾನ ರೂಪಕ ಲಾಭಗಳು ಹಾಗೂ ಪದವಿ ಪೂರ್ವ ಕಾಲೇಜುಗಳಿಗೆ
ಈಗಾಗಲೇ ನಿರ್ಮಾಣಗೊಂಡಿರುವ ಹಳೆಯ ಕಟ್ಟಡಗಳಿಗೆ Structural Stability
ನಿರೀಕ್ಷಣಾ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನೀಡುವ ಕುರಿತು.

- ಉಲ್ಲೇಖ:-1) ಮಾನ್ಯ ಸರ್ಕಾರ ಸುತ್ತೋಲೆ ಸಂಖ್ಯೆ ಲೋಕ 59 ಪೂ/2019 ದಿನಾಂಕ:-07-05-2022.
2) ಮಾನ್ಯ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧಿಯಂತರು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ವಿಭಾಗ ಚಿಕ್ಕೋಡಿ
3) KLE Collage of Engineering & Technology Chikkadi ಕವರ ಪತ್ರ ಸಂಖ್ಯೆ:396/
032-11-2025.
4) Head Master J.E.Society's Shri.Pratap Jadhavji Bhat English Medium School Athani
ರ ಪತ್ರ ದಿ:17-11-2025.

ಮೆಲ್ಟಾಚಿಸಿದ ವಿಷಯ ಹಾಗೂ ಉಲ್ಲೇಖ:-1) ಕೆ. ಸಂಸ್ಥೆಯ ಸ್ವೀಕೃತ ಪ್ರತಿಪಾದನಾಧಾರಿತ ಫಲಿತಾಂಶ ಮೂಲಕ, ಶಾಲೆಯ ಕಟ್ಟಡಗಳ ನಿರ್ಮಾಣ ಪತ್ರಿಕೆಯನ್ನು ನೀಡಲು ಉಲ್ಲೇಖ (4)
ರಲ್ಲಿ ವಿವರಿಸಿದ್ದು.

ಉಲ್ಲೇಖ:-2ರ ಸರಕಾರ ಸುತ್ತೋಲೆಯ ನಿರ್ದೇಶನದಂತೆ ಈಗಾಗಲೇ ನಿರ್ಮಾಣಗೊಂಡ ಅಸ್ತಿತ್ವದಲ್ಲಿರುವಂತಹ
ಕಟ್ಟಡಗಳಿಗೆ ರಚನಾತ್ಮಕ (Structural Evaluation) ಮೌಲ್ಯಮಾಪನ ಮಾಡಿಸಿ National Building code ಮಾನದಂಡಗಳ
ಅನ್ವಯ ಹಾಗೂ ಉಲ್ಲೇಖ (2)ರ ಪತ್ರದಲ್ಲಿ ಮಾನ್ಯ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧಿಯಂತರು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ವಿಭಾಗ ಚಿಕ್ಕೋಡಿ
ಇವರು ಸಹ ಈ ಪತ್ರದಲ್ಲಿ ಸ್ಪಷ್ಟಕರಿಸಿರುವ ಪ್ರಕಾರ ನಿರೀಕ್ಷಣಾ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನೀಡಲು ಸೂಚಿಸಿರುತ್ತಾರೆ.

ಸದರಿ ಪ್ರಸ್ತಾವನೆಯೊಂದಿಗೆ ಅಗತ್ಯವಿರುವ ಮಾಹಿತಿಗಳನ್ನು ಪರಿಶೀಲಿಸಿದ್ದು Non Destructive test ಗಳನ್ನು
ಕ್ರಿಯಾತ್ಮಕ ಕಟ್ಟಡವನ್ನು ಮೌಲ್ಯಮಾಪನದಲ್ಲಿ ಕೂಡಿಸುವುದಾಗಿ ಪರಿಶೀಲಿಸಿ ಅಭಿಪ್ರಾಯವನ್ನು ನೀಡಲು S.N.J.P.N.Trusts
Polytechnic Nidasoshi ದಿ:-12-11-2025, ಅದರ ಪ್ರತಿಯನ್ನು ಉಲ್ಲೇಖ:-3 ರ ಪತ್ರದಲ್ಲಿ ಕಟ್ಟಡವು ಸಮಗ್ರವಾಗಿ ಇರುತ್ತದೆ.

ಈ ವಿಷಯ ಪರಿಶೀಲಿಸಿ ಅಥಣಿ ತಾ. ಜಿ.ಉ. ಸಂಸ್ಥೆಯ ಸ್ವೀಕೃತ ಪ್ರತಿಪಾದನಾಧಾರಿತ ಫಲಿತಾಂಶ ಮೂಲಕ, ಶಾಲೆಯ ಕಟ್ಟಡಗಳ
NBC-2016 ಮಾನದಂಡಗಳನ್ನು ಪರಿಶೀಲಿಸಿ ಕಟ್ಟಡವು ಸುರಕ್ಷಿತವಾಗಿರುತ್ತದೆ. ಸದರಿ ಪ್ರಮಾಣ
ಪತ್ರ 05 ವರ್ಷದ ಅವಧಿವರೆಗೆ ಅನ್ವಯಿಸುವುದಿರುತ್ತದೆ ಈ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಈ ಕೆಳಗಿನ ವಿವರಗಳಲ್ಲಿ ನೀಡಲಾಗಿದೆ.

- 1) ಕಟ್ಟಡದಲ್ಲಿ ಯಾವುದೇ ಬದಲಾವಣೆ ಮಾಡಬೇಕಾದಲ್ಲಿ ಕಾರ್ಪಸ್ ಸಹಿತ ವಡೆದು ಕೈಗೊಳ್ಳುವುದು.
- 2) ಕಟ್ಟಡದ ನಿರ್ಮಾಣಾತ್ಮಕ ನಿರ್ಮಾಣದ ಯಾವುದೇ ಬದಲಾವಣೆ ಕೈಗೊಳ್ಳುವುದು.
- 3) ಇದನ್ನು ಕಟ್ಟಡವನ್ನು ಕಾರ್ಪಸ್ ನಿರ್ಮಾಣಾತ್ಮಕ ಮಾತ್ರ ವಿಳಾಸವು.

ತಮ್ಮ ವಿಶ್ವಾಸ,

ಸಮಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧಿಯಂತರು
ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ಉಪ ವಿಭಾಗ ಅಥಣಿ

HEAD MASTER

J. E. Society's
Shri Pratap Jadhavji Bhat
English Medium School,
Athani-591304.

Government of Karnataka
Assistant Executive Engineer, Public Works Department, Sub-Division Athani
Phone Number- E-Mali-aeeppwdan1@gmail.com

To,
Head Master
J.E.Societys Shri. Pratap Jadhavji Bhate
English Medium School Athani

Dear sir,

Subject:- Regarding issuance of Structural Stability Certificate to old buildings that have already been demolished for private aided and unaided schools and pre-university colleges.

Ref : 1) Hon'ble government circular No.LE59DED/2019 Date : 07-05-2022.

2) Hon'ble Executive Engineer, Public Works Department, Chikkodi Division

3) KLE College of Engineering & Technology Chikkodi certificate No.396/
dt:12-11-2025,

4) Head Master J.E. Societies Shri. Pratap Jadhavji Bhate English Medium School Athani dt:17-11-2025.

As per the content and reference Athani J.E. Societies Shri. Pratap Jadhavji Bhate English Medium School/Institute has requested in reference (4) to provide a safety certificate.

As per the direction of the Government Circular in Reference-1, the existing (Structural Evaluation) National Building Code application and in the letter in Reference (2), the Honorable Managing Engineer, Public Works Department, Chikkodi, has also directed to issue a certificate of non-requirement according to structural stability.

The samples attached with the said proposal have been examined and Non Destructive tests have been conducted at S.N.J.P.N.Trusts Polytechnic Nidasoshi dtd:12-11-2025. Their copy is in the letter of reference-3 and the building will be strong.

Having examined all these conditions, it is concluded that the buildings of J.E. Institute's Shri. Pratap Jadhavji Bhate English Medium School have met the NBC-2016 standards and are safe to build. The said certificate is valid for a period of 05 years. This certificate is issued subject to the following conditions

- 1) If any changes need to be made to the building, technical advice should be sought and implemented.
- 2) To undertake the management of Kannada periodicals from time to time.
- 3) Use the building only for school making.

Yoursself.

Assistant Executive Engineer,
Public Works Department,
Sub-Division Athani


SECRETARY


J. E. Society

Athani-591304. Dist:Belagavi.


Head Mistress
Shri Pratap Jadhavji Bhate
English Medium School,
Athani-591304



Verified & found Correct


S. V. Chougala
Notary Govt. of India
ATHANI. Dist: Belagavi.
Mob: 9448194975

